

BARDAGE SANDWICH 100-TS

R DB

DATE: 27/10/89

FORGES D'HAIRONVILLE


ESSAIS CSTB OCTOBRE 89 ISOLEMENT HORIZONTAL

RAPPORT: 1.../5

1001 TS-60


POSTE: D

COUPE A-A



- 1: PROFIL 1-1000-4-1 ep. 0.63
- 2: PROFIL 3-333-39-1 ep. 0.63
- 3: MOUSSE DE POLYURETHANE

**HAIRONVILLE SA**  
 55000 HAIRONVILLE  
 TEL. 29.79.85.85  
 TELEEX 961 582  
 TEGEFAX 29.45.15.10



$R_{rose} = 25 \text{ dB(A)}$

$R_{route} = 22 \text{ dB(A)}$

