




MUZ-SF25VE MUZ-SF25VEH



OUTDOOR UNIT


FUNCTION	SPL(dB(A))	LINE
COOLING	47	
HEATING	48	



MUZ-SF35VE MUZ-SF35VEH



OUTDOOR UNIT


FUNCTION	SPL(dB(A))	LINE
COOLING	49	
HEATING	50	



MUZ-SF42VE MUZ-SF42VEH



OUTDOOR UNIT


FUNCTION	SPL(dB(A))	LINE
COOLING	50	
HEATING	51	



MUZ-SF50VE MUZ-SF50VEH

OUTDOOR UNIT

FUNCTION	SPL(dB(A))	LINE
COOLING	52	
HEATING	52	






<Notes>

- 1) Sound data is taken when the system is running stably.
- 2) Relatively large noise could be heard transiently in the case 4-way valve, or LEV operates.

MUZ-GF60VE



OUTDOOR UNIT


FUNCTION	SPL(dB(A))	LINE
COOLING	55	
HEATING	55	



MUZ-GF71VE



OUTDOOR UNIT


FUNCTION	SPL(dB(A))	LINE
COOLING	55	
HEATING	55	



MUZ-HJ25VA



OUTDOOR UNIT


FUNCTION	SPL(dB(A))	LINE
COOLING	50	
HEATING	50	



MUZ-HJ35VA

OUTDOOR UNIT

FUNCTION	SPL(dB(A))	LINE
COOLING	50	
HEATING	50	



<Notes>
1) Sound data is taken when the system is running stably.
2) Relatively large noise could be heard transiently in the case 4-way valve, or LEV operates.