


SCHALLABSORPTIONSGRAD (HALLRAUM-METHODE) ZUSAMMENFASSUNG

612.2352

Beilage 36

Kurven Nr.	Aufbau	Schallabsorptionsgrad										Schallabsorptionsgrad α_s			
		Einzelwerte α_s										Mittelwerte			
		160	320	630	1250	2500	5000	10000	20000	40000	80000	tief	mittel	hoch	gesamt
10		.23	.72	.109	.55	.29	.38					0.32	0.89	0.36	0.53
11		.14	.63	.108	.72	.43	.40					0.28	0.92	0.44	0.55
12		.32	.95	.99	.47	.31	.35					0.46	0.84	0.34	0.55
13		.28	.93	.106	.66	.40	.38					0.42	0.91	0.43	0.59
14		.41	.107	.89	.47	.35	.36					0.56	0.77	0.36	0.57

Auftrags-Nr.
162 452Auftraggeber:
Flumroc AG, FlumsGezeichnet:
8.12.82

Zeichnungsnummer:

831